

Sub :- Tender Notice No: NITR/CT-13/2014-15

Record Note of Prebid Meeting held on 29-01-2014

Design, Engineering, Supply and Installation of Exhaust Hood, Blowers, Ducting for Kitchen Equipment for Hostel.

1. EMD shall be Rs. 3.00Lakhs insted of 2%.
2. Material of construction for Exhaust Hood shall be stainless steel of Grade 304.
3. Blower shall be installed outdoor either on the terrace or on the plinth protection area to suit the site condition as per the direction of Engineer in charge.
4. Civil work related to installation of equipment is in the scope of the tenderer /supplier.
5. The dimensions mentioned in the BOQ are approximate.